CHQ MODULES INSTALLATION INSTRUCTIONS

Products Covered: CHQ SZM (Single Zone Monitor), CHQ-DIM (Dual Input Monitor), CHQ-DZM (Dual Zone Module)



Introduction

The CHQ "Smart-Fix" Range of Modules consists of the following models:

CHQ-DIM(SCI) CHQ-DIM/M(SCI) CHQ-DIM/DIN(SCI)	Dual Input Module	CHQ-DZM(SCI)) CHQ-DZM/DIN(SCI)	Dual Zone Monitor
CHQ-DRC(SCI) CHQ-DRC/M(SCI) CHQ-DRC/DIN(SCI)	Dual Relay Controller	CHQ-MRC(SCI) CHQ-MRC/DIN(SCI)	Mains Relay Controller
CHQ-DSC(SCI)		CHQ-SZM(SCI)	
CHQ-DSC/M(SCI)	Dual Sounder Controller	CHQ-SZM/M(SCI)	Single Zone Monitor
CHQ-DSC/DIN(SCI)		CHQ-SZM/DIN(SCI)	

Note: (SCI) indicates Module incorporates a short-circuit isolator. DIN indicates Module housing is designed to fit standard "Top Hat" DIN Rail.

Components

Standard "Smart-Fix" Modules (including (SCI) versions) are supplied as two individual components (see Fig 1 & 2). DIN versions are supplied as one unit (see Fig 3).





Setting the Loop Address

- The analogue address of the Module is set using the first 7 switches of the 8-bit DIL switch, which in the case of the Standard CHQ is located through the cut-out section on the top of the PCB cover. On the DIN version, this switch is located on the edge of the PCB behind the clear door (see Fig 3).
- The switches are numbered 1 to 8 (left to right):

	SWITCH UP	ON		
		SWITCH DOWN	OFF	
		SWITCH UP	OFF	—
		SWITCH DOWN	ON	_

 The switches should be set using a small-tipped screwdriver or similar.

Refer to the Address Chart (Fig 9) on page 4 for a quick reference on addresses.

(continued on page 4)



CHQ-LID Transparent Module Lid

(Supplied with four screws and acrylic retaining washers)



Fig 3

DIN Rail Mountable CHQ Module



Hochiki Europe (UK) Ltd

Standard EOL Options for	CHQ-DZM	
EOL Option Type	Part	Description
OPTION 1 Zener End of line device (Zone)	TE-RH-E Hochiki Part No 2-1-1-016	(Iz=1-mA, T=30ms, Vz=22.7 to 24.3 V) L terminal connects to +Zone C Terminal connects to -Zone
OPTION 2 Active End Of Line Module (Zone) Active End Of Line <i>in conjunction with</i>	LCMU (6K8) Hochiki Part No 1270070-00 (SUPPLIED SEPARATELY)	Active EOL - Line Continuity Monitoring Unit for Schottky bases (See Fig 6) Pink lead connects to +Zone Black lead connects to –Zone
Capacitor (Zone)	47 μF Capacitor Hochiki Part No (2-2-7-031)	47 μF ±20% 35 V Fitted directly into Zone terminals (see Fig 6)
OPTION 3 Resistive EOL (Zone)	6K8 resistor (2-2-5-1015)	6K8 ± 5% 0.4 W
Monitored input EOL	10 KΩ resistor (2-2-5-806)	10 KΩ ± 5% 0.4W





Fig 7

CHQ-SZM SINGLE ZONE MONITOR is a loop-powered module that provides a single fully monitored input for the connection of up to six Hochiki conventional smoke or heat detectors, OR one Hochiki beam detector, or any number of conventional call points, the unit also contains an output for remote fire indication.

Note: The end of line device (EOL) is supplied with the unit – **do NOT discard in error!** The EOL device MUST be fitted at the last detector on the zone, note the polarity.



Order codes		CHQ-SZM(SCI) / CHQ-SZM/M(SCI) / CHQ-SZM/DIN(SCI) *1			
Transmission method		Digital communication using ESP			
Loop:-Operating vol	tage	17 - 41 VDC			
Quiescent cu	rrent	260 μΑ			
Current consumption whilst polling		22 mA ± 20 %			
Current in short-circuit		8 mA			
Maximum short-circuit current (Loop)		1 A	1A		
E.O.L device		TE-RH-E (polarity conscious)			
Zone voltage		15.3 V - 17.	15.3 V - 17.1 V		
Zone resistance		50 Ω (Max)			
Zone capacitance		0.3 μF (Max)			
Detectors per zone		DCA, DFB, DFE – No limit, SLG, SLK, SLR, SIF, SIH, SIJ, DCC, DCD, DFJ – 6 max SPB-ET or SRA-ET– Only one and no other detectors, HF-24 – Only one and no other detectors, DRD-E – 3 max, Conventional Call Points – No limit			
Weight (g) & Dimensions (mm)	CHQ-SZM(SCI) CHQ-SZM/M(SCI)	328	L157 x W127 x D35 (CHQ Module plus Lid) D79 (CHQ Module plus Lid plus CHQ-BACKBOX)		
	CHQ-SZM/DIN(SCI)	114	(add 235 to module weight when using CHQ-BACKBOX) L108 x W119 x D24 (CHQ DIN Module)		
Colour and enclosure material		CHQ Modu	CHQ Module & CHQ-BACKBOX White ABS, DIN Module Green ABS		
* Fire alarm control pa	anel compatibility required for	these products.	See AP0127 for short-circuit isolator specifications.		

This module does not support any line continuity options; therefore, if Manual Call Points are to be interfaced then these should be connected first.

Installation – "Smart-Fix" Version

Set analogue address before installation (see page 1). The fixing surface should be dry and stable.

- Hold the back plate up against the fixing surface and mark the position of the four corner fixing holes.
- Determine which cut-out sections along the top and bottom edges of the module require removing to accommodate the cables being used.
- Remove cut-outs by scoring with a sharp knife before breaking off with pliers or snips.
- Mount the back plate using appropriate fixings (not supplied) for the fixing surface.
- Terminate and connect field wiring as per the wiring diagrams on pages 2 & 3 (and the terminal block indications on the product label).

The transparent lid (CHQ-LID) is supplied with four screws and eight retaining washers.

- Push the screws through one of the retaining washers and then through the holes in the lid from front to back, pushing another retaining washer onto the end inside the lid.
- Screw the lid onto the back plate; do not over tighten the screws as this could damage the unit.

Note, a white plastic version of the lid is available (sold separately – CHQ-LID(WHT)).



Installation with Back Box

Fig 9

For CHQ-DIM or CHQ-SZM installations requiring glanded cables, a module back box (CHQ-BACKBOX) is available (sold separately). This is mounted on the fixing surface; the CHQ Module is then fitted to the top of the back box and the CHQ-LID is added creating a sealed enclosure. For further details refer to the CHQ-BACKBOX Instructions (2-3-0-800). For CHQ-DZM installations utilising heavy-duty cabling (for example, 1.5mm² solid conductor) the use of the SMB-1 Box with the SMB-ADAPTOR plate and CHQ-ADAPTOR is recommended. For further details refer to the SMB-ADAPTOR Instructions (2-3-0-1502). Ensure any glands used (not supplied) conform to IP67, if such ingress protection is required.

Installation – DIN Version

Set analogue address before installation (see page 1) and write loop address in space provided on door label.

- DIN modules should be mounted in a suitable enclosure in conjunction with an NS 35 mounting rail with the loop connections at the bottom of the unit. Hochiki recommends the SMB-2 and SMB-3 Boxes designed specifically for this purpose.
- Terminate and connect field wiring as per the wiring diagrams on pages 2 & 3 (and the terminal block indications on the product label).
- Suitable anti-static precautions must be taken when handling these products.

Status LEDs

Refer to the table below for Status LED indications:

CHQ-DIM (all variants)	Dual Input Module	Green LED flashes each time the unit is polled by the fire alarm
CHQ-SZM (all variants)	Single Zone Monitor	control panel and is continuously illuminated when either input is active (CHQ-DIM only) Amber I ED is continually illuminated
CHQ-DZM (all variants)	Dual Zone Monitor	when unit detects short-circuit fault.

	CHQ-DIM(SCI)	0832-CPD-1098	09	
Protocol specified in TI/006	CHQ-SZM(SCI)	0832-CPD-1094	09	
	CHQ-DIM/DIN(SCI)	0832-CPD-1099	10	EN54-17 Short Circuit Isolators
	CHQ-SZM/DIN(SCI)	0832-CPD-1095	10	EN54-18 Input/Output Modules
	CHQ-DZM(SCI)	0832-CPD-1657	11	
	CHQ-DZM/DIN(SCI)	0832-CPD-1658	11	



Hochiki Europe (UK) Ltd Grosvenor Road, Gillingham Business Park, Gillingham, Kent, ME8 0SA, England Telephone: +44(0)1634 260133 Facsimile: +44(0)1634 260132 Email: sales@hochikieurope.com Web: www.hochikieurope.com Hochiki Europe (UK) Ltd. reserves the right to alter the specification of its products from time to time without notice. Although every effort has been made to ensure the accuracy of the information contained within this document it is not warranted or represented by Hochiki Europe (UK) Ltd. to be a complete and up-to-date description. Please check our web site for the latest version of this document.