



CSIRO Verification Services Clayton, Victoria, Australia +61 (0)3 9545 2777 http://www.activfire.gov.au/

#### **Certificate of Conformity** Certificate num. **Registration date** Version Valid until Number Issue date Page 1 of 3 afp - 3060 10-Oct-2016 30-Apr-2018 10-Oct-2016 1 This certification is issued within **Product designation** the scope of CSIRO Verification Services – Rules governing ActivFire Hochiki, IFD-E Series, Triple Infra-red, IR<sup>3</sup> flame detector Scheme and is valid only for the product(s) as submitted for (Refer to the Schedule/enclosures for further specified details) evaluation and verification of conformity, subject to the following Agent/distributor conditions Reference to details, limitations Hochiki Australia Pty Ltd and requirements, where 391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143 documented as a schedule/enclosure with this certificate Registrant The Registrant is responsible for

Hochiki Australia Pty Ltd

391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

Producer

Talentum Developments Ltd Beal Lane, SHAW, OLDHAM, UNITED KINGDOM, OL2 8PF

### **Conformance criteria and evaluation**

The Hochiki, IFD-E Series, Triple Infra-red, IR<sup>3</sup> flame detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

European Standard EN 54-10:2002, 'Fire detection and fire alarm systems. Flame detectors. 1. Point detectors'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- Compatibility of this fire detector and its base assembly with new or existing control and i. indicating equipment should be verified prior to installation.
- Intrinsically safe unit shall only be installed with approved barriers as specified by the ii. producer/manufacturer.

- their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services



David Whittaker Executive Officer – ActivFire Scheme



Issued by

#### © CSIRO Australia, 2016

This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time. The validity and authenticity of this certificate can be verified by the certification register located at http://www.activfire.gov.au

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Ve	rsion	Valid until	
afp - 3060	10-Oct-2016	Number 1	Issue date 10-Oct-2016	30-Apr-2018	Page <b>2</b> of <b>3</b>

### **Producer's description**

The Hochiki, IFD-E Series, Triple Infra-red, IR<sup>3</sup> flame detector is designed for use where open flaming fires may be expected and responds to the light emitted from flames during combustion.

The detector discriminates between flames and other light sources by responding only to particular optical wavelengths and flame flicker frequencies. This enables the detector to avoid false alarms due to such factors as flickering sunlight. Ideal for the detection of flames from the burning of Aviation Fuels (kerosene), Butane, Grain & Feeds, Hydrogen, Paper, Natural Gas, Petrol (gasoline) etc.

### **Technical specification**

The following details are a representative extract of the technical specification for the Hochiki, IFD-E Series, Triple Infra-red, IR<sup>3</sup> flame detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

#### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant						
Туре	Ident.	Other element	Circuit configuration	Description		
Model IFD-E IFD-E(EXD) IFD-E(IS)		016589	Conventional	Infra-red Flame Detector		
	IFD-E	016689	Analogue addressable			
		016519	Conventional	Infra rad Elama Datastar, Alloy Elamonroof		
	016619	Analogue addressable	Infra-red Flame Detector, Alloy Flameproof			
	IFD-E(IS)	016579	Conventional	Infra rad Elama Datastar, Intrinsically Safa		
		016679	Analogue addressable	Initia-reu Fiante Detector, Intrinsically Sale		

#### Schedule of properties/characteristics

Property/characteristic		IFD-E	IFD-E(IS)	IFD-E(EXD)		
Operating voltage		14 – 30 Vdc				
Alarm current (selected via by DIL switches)		3 ~ 28 mA				
Test signal voltage		14 to 30 Vdc				
Relay contact ratings	Current	1.0 A (max)				
	Voltage	50 Vdc (max)				
	Power	30 W (max) (resistive loads only)				
Power up time		2 seconds (max)				
Field of view		90° min. Cone				
_		Class 1 – 0.1 m2 n-heptane at 25 m				
Range		Class 3 – 0.1 m2 n-heptane at 12 m		m		
Operating wavelength band			IR (0.75 ~ 2.7 μm)			
Operating temperature range		-10°C to + 55°C (sensor limit -10°C to +40°C (T4))				
Storage temperature range		-20°C to + 65°C				
Maximum humidity		95% RH - Non condensing (at 40°C)				
Ingress protection rating		IP65	IP65	IP66		
Colour / Case material		Blue / Die-Cast Zinc Alloy	Blue / Die-Cast Zinc Alloy	Red / Copper Free		
		(ZA12)	(ZA12)	Aluminium Alloy LM25		
Weight (Kg)   Height / Width / Depth (mm)		2   142 / 108 / 82	2   142 / 108 / 82	2.5   150 / 146 / 137		

#### Schedule to **Certificate of Conformity** Certificate num. Registration date Version Valid until Page **3** of **3** Number Issue date afp - 3060 10-Oct-2016 30-Apr-2018

# Supplementary information

1

10-Oct-2016

#### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference			Data issued	
Ident. type	Ident.	Title / description	(or date validated)	Source
Test report number	TE219534	Technical evaluation of a Talentum Developments Ltd model 016000 series conventional and analogue addressable IR <sup>3</sup> flame detectors to the requirements of EN 54-10: 2002 and Agreement Document AD13.1 Draft in accordance with LPCB test schedule E120379/1.1	26-Aug-2006	BRE Testing, UK
LPCB Ref. No.	164m/01	Conventional IR <sup>3</sup> Flame detector (IFD-MB) Certificate No 164m to EN54-10:2002 (lpcb_w3_Cert_164m_v_2016-08-10.pdf)		
	164m/02	Conventional IR <sup>3</sup> Intrinsically Safe Flame Detector (IFD-MB) Certificate No 164m to EN54-10:2002 (lpcb_w3_Cert_164m_v_2016-08-10.pdf)	8-Oct-2016 BRE Global Ltd, LPCB, UK	
	164m/03	Conventional IR <sup>3</sup> (Exd) Flameproof Flame Detector (IFD-MB) Certificate No 164m to EN54-10:2002 (lpcb_w3_Cert_164m_v_2016-08-10.pdf)		
Doc. ld.	2-3-0- 808/ISS4/JAN14	Hochiki IFD-E Flame Detector User Manual	11-Mar-2014	
	2-3-0- 809/ISS2/JUL07	Hochiki IFD-E(IS) Intrinsically Safe Flame Detector User Manual	12-Jul-2007	Hochiki Europe (UK) Ltd, UK
	2-3-0- 810/ISS3/OCT11	Hochiki IFD-E(Exd) Explosion-Proof Flame Detector User Manual	4-Oct-2011	
DoP No.	IFD-E 589CPR2013- 08-15	Declaration of Performance Conventional, IS, IR3 flame detector – Point detector IFD-E EN54-10:2002 + A1:2005 Certificate of constancy of conformity, 0832-CPD-0595	15-May-2013	
	IFD-E(IS) 579CPR2013-08-15	Declaration of Performance Conventional, IS, IR3 flame detector – Point detector IFD-E(IS) EN54-10:2002 + A1:2005 Certificate of constancy of conformity, 0832-CPD-0597	15-Aug-2013	Talentum Developments Ltd, UK
	IFD-E(ExD) 519CPR2013-08-15	Declaration of Performance Conventional, Exd, IR3 flame detector – Point detector IFD- E(ExD), EN54-10:2002 + A1:2005 Certificate of constancy of conformity, 0832-CPD-0599	15-Aug-2013	