



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2721	14-Feb-2012	3	30-Apr-2015	Page 1 of 2

Product designation

Hochiki, Model SLV-AS3, photoelectric smoke detector
(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Hochiki Australia Pty Ltd
Unit 3, 165 Rookwood Road, YAGOONA, NSW, AUSTRALIA, 2199

Registrant

Hochiki Corporation
10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Producer

Hochiki Corporation
10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Conformance criteria and evaluation

The Hochiki, Model SLV-AS3, photoelectric smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.7-2004, 'Fire detection and alarm systems - Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this equipment with new or existing actuating devices should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2721	14-Feb-2012	3	30-Apr-2015	Page 2 of 2
		Number 3	Issue date 24-Apr-2014	

Producer's description

The Hochiki, Model SLV-AS3, photoelectric smoke detector uses a photoelectric sensing chamber to detect the presence of smoke. The smoke detector has a two light emitting diodes (LED) mounted on the printed circuit board within the housing, which remains static during normal operation and indicates steady red when the smoke detector is in the alarm condition.

Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model SLV-AS3, photoelectric smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Light source:	Infrared LED
Nominal rated voltage:	24 Vdc
Rated voltage (filtered dc):	9.5 ~ 30.0 Vdc
Maximum allowable voltage:	42 Vdc
Supervisory current:	35 μ A at 24V, 25°C
Surge current :	160 μ A max. at 24V, 25°C
Maximum switching current:	80 mA max. at 25°C
Minimum alarm trip current:	6 mA at 25°C
Operating temperature range:	-10°C ~ +50°C

Verified base designation	Base + detector circuit type
Hochiki, Model YBN-R6	Conventional
Hochiki, Model YBO-R/6PA	Conventional
Hochiki, Model YBN-R/6SK	Conventional
Hochiki, Model YBO-R/6RN	Conventional
Hochiki, Model YBO-R/6RS	Conventional