



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 3190	12-Sep-2017	Number 2	Issue date 26-Apr-2019	30-Apr-2020
				Page 1 of 2

Product designation

Hochiki, Model SOC-AS3, photoelectric smoke detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Hochiki Australia Pty Ltd
391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

Registrant

Hochiki Australia Pty Ltd
391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

Producer

Hochiki Corporation
10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Conformance criteria and evaluation

The Hochiki, Model SOC-AS3, photoelectric smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.7-2004, 'Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 3190	12-Sep-2017	Number 2	Issue date 26-Apr-2019	30-Apr-2020

Page 2 of 2

Producer's description

The Hochiki, Model SOC-AS3, photoelectric smoke detector uses a photoelectric sensing chamber to detect the presence of smoke. The detector has one light emitting diode (LED), mounted on the detector housing, which remains in the static off condition during normal operation. When the detector is in the alarm condition, the indicator is illuminated red (steady). The LED may also indicate a fault condition, by flashing once every 3 seconds, when contamination is identified by the drift compensation algorithm.

This device is 100 mm diameter and has a height of approximately 45 mm when connected to the mounting base assembly.

Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model SOC-AS3, photoelectric smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Operating voltage	9.5 to 30 Vdc
Average current consumption (Normal condition) (Trouble condition)	35 μ A (Typ) at 24 Vdc 120 μ A (Max) at 24 Vdc
Rating current	80 mA (Max)
Current to keep in alarm	5 mA (Max)
Time to reset	> 100 msec
Operating temperature	-10 to 50°C
Installation location temperature	-30 to 60°C
Humidity	< 40°C : < 95%Rh < 60 °C : < 80%Rh
Dimensions	100 mm diam. x 45 mm H (not including base)

Schedule of components and/or assemblies

The following is a schedule of validated components and/or assemblies of the certified/listed equipment.

Base designation	Description	Detector + base connection type
Hochiki, YBN-R/6	standard base	Conventional
Hochiki, YBO-R/6PA	2-wire base	
Hochiki, YBO-R/6R	relay base	
Hochiki, YBO-R/6RN	relay base, non-latching	

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3144/R1	Evaluation for conformity of the Hochiki Model SOC-AS3 Conventional Smoke Detector to the requirements of AS 7240.7-2004	24-Aug-2017	CSIRO, Fire Systems Laboratory, AU
Ref No.	7-0-000-4836-721	Technical Specification (Model SOC-AS3)	26-Apr-2017	Hochiki Corporation, JP